



Certificate of Compliance

This certificate is issued for the following:

Non-Gasketed Pipe Fittings for Use with Aboveground Fire Protection Systems

Malleable Iron Non-Gasketed Fittings Manufactured to
JIS B2301 Specifications

with a Rated Working Pressure of 363 psi (2500 kPa)

Prepared for:

PT Tri Sinar Purnama
Jl Moch Ichsan RT 01/ RW 01 Kelurahan Wates
Kecamatan Ngaliyan
Semarang 50188
Indonesia

Manufactured at:

PT Tri Sinar Purnama
Jl Moch Ichsan RT 01/ RW 01 Kelurahan Wates
Kecamatan Ngaliyan
Semarang 50188
Indonesia

FM Approvals Class: 1920 – “Pipe Couplings and Fittings for Aboveground Fire Protection Systems”

Approval Identification: 3063220

Approval Granted: June 22, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group