



Certificate of Compliance

This certificate is issued for the following:

Pipe Couplings and Fittings for Aboveground Fire Protection Systems

Pipe Fittings

Models 19A, 3, 6, 21A, 26, 13, 14, 35B, 35C, 7B, 6B, 24B, 31A, 4, 30

Sizes 1/8 to 6 inch NPS

Prepared for:

PT Tri Sinar Purnama
Jl Moch Ichsana RT 01/ RW 01 Kelurahan Wates
Kecamatan Ngaliyan Semarang, 50188
Indonesia

Approval Standard: FM 1920 (November 2007)

Approval Identification: PR461036

Approval Granted: July 12, 2022

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'David B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group

