



# Certificate of Compliance

This certificate is issued for the following:

## Non-Gasketed Pipe Fittings for Use with Aboveground Sprinkler Systems

Malleable Iron Non-Gasketed Fittings Manufactured to EN 10242 Specifications  
with a Rated Working Pressure of 363 psi (2500 kPa)

### Prepared for:

PT Tri Sinar Purnama  
JI Moch Ichsan RT 01/ RW 01 Kelurahan Wates  
Kecamatan Ngaliyan  
Semarang 50188  
Indonesia

### Manufactured at:

PT Tri Sinar Purnama  
JI Moch Ichsan RT 01/ RW 01 Kelurahan Wates  
Kecamatan Ngaliyan  
Semarang 50188  
Indonesia

FM Approvals Class: 1920 – “Pipe Couplings and Fittings for Aboveground Fire Protection Systems”, dated November, 2007

Approval Identification: PR449886

Approval Granted: March 20, 2019

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller  
VP - Manager of Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA



*Member of the FM Global Group*